

**FORM VI**

**BOILER INSPECTORATE DEPARTMENT**

**CERTIFICATE FOR USE OF A BOILER**

( Regulation 389 )

Registry Number of Boiler DNH-03      Type of Boiler. Horizontal Smoke Tube.  
Shell Type fully wetback.

Boiler Rating 174 Sq.mts.      Place and year of manufacture Vapi 2009.

Maximum continuous Evaporation 6000 Kg/Hr.

Name of Owner      M/s. Bhilosa Industries Pvt. Ltd., Village – Rakholi

Situation of Boiler      Srv. No. 37 & 46/1/3/1, Rakholi.

Repairs      -

Remarks      Boiler to be operated by Qualified Boiler Attendants.

Hydraulically Tested on      06.06.2017      to      21Kg/Cm<sup>2</sup>      Ibs. per sq. inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 200 PSI Ibs. to the square inch for period from 06.06.2017 to 05.06.2018.

The loading of the 2nos 40mm Ø S.L. safety valve is not to be exceed 250 PSI.

I further certify that the main steam-pipe was tested hydraulically to a pressure of Ibs. per square inch last on

Fee Rs. 4500/-

Paid on: 16.05.2017.

Dated at Silvassa.

This 06.06.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.  
Chief Inspector of Boilers  
Administration of Dadra & Nagar Haveli  
SILVASSA