

**FORM VI**

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

( Regulation 389 )

Registry Number of Boiler DU-18

Type of Boiler. Hor. Multitubular Shell type  
Smoke Tube Wetback.

Boiler Rating 114.01 Sq.mts.

Place and year of manufacture Pune 2008.

Maximum continuous Evaporation 3000 Kg/Hr.

Name of Owner M/s. Micro Inks Ltd. (M/s. Hubergroup India Pvt. Ltd.)

Situation of Boiler. Jani Vankad, Daman.

Repairs -

Remarks Boiler to be operated by Qualified Boiler Attendant.

Hydraulically Tested on 13.06.2017 to 275 PSI lbs. per sq. inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 150 PSI lbs. to the square inch for the period from 13.06.2017 to 12.06.2018.

The loading of the 40 x 80mmØ S.L. safety valve is not to exceed 150 PSI.

I further certify that the main steam-pipe was tested hydraulically to a pressure of lbs. square inch last on

Fee Rs. 4500/-

Paid on: 29.05.2017.

Dated at Daman.

This 13.06.2017.

Inspector

Countersigned.

Chief Inspector of Boilers  
Admn. of Daman & Diu (U.T.)  
DAMAN