

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

( Regulation 389 )

Registry Number of Boiler DNH-20

Type of Boiler. Hor. Multitublar  
Shell type Boiler.

Boiler Rating 104 Sq.mts.

Place and year of manufacture Pune 2010.

Maximum continuous Evaporation 5000 Kg/Hr.

Name of Owner M/s. IPCA Laboratories Ltd.

Situation of Boiler Plot No.225/1, Athal, Silvassa.

Repairs -

Remarks Boiler to be operated by Qualified Boiler Attendant.

Hydraulically Tested on 09.05.2017 to 225 PSI Ibs. per sq. inch

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 150 PSI for the period from 09.05.2017 to 08.05.2018.

The loading of the 2nos 40 x 80 C.S safety valve is not to exceed 150 PSI.

I further certify that the main steam-pipe was tested hydraulically to a pressure 300 PSI inch last on 10.06.2011.

Fee Rs. 4000/-


Paid on: 29.04.2017.

Dated at Silvassa.

This 09.05.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.