

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler DU-13

Type of Boiler. Horizontal Multitubular Shell
Smoke tube.

Boiler Rating 43 Sq. mts.

Place and year of manufacture Pune 2001.

Maximum continuous Evaporation 1500 Kg/Hr.

Name of Owner M/s. Indchemie Health Specialities Pvt. Ltd.

Situation of Boiler. Plot No. 7, OI DC, Dabhel, Daman.

Repairs -

Remarks Boiler to be operated by qualified Boiler Attendant.

Hydraulically Tested on 23.01.2017 to 275 PSI lbs. per sq.inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 150 lbs. to the square inch for the period from 23.01.2017 to 22.01.2018.

The loading of the 2 nos 25.4 mm Ø S.L. safety valve is not to exceed 150 PSI.

I further certify that the main steam-pipe was tested hydraulically to pressure of lbs. per square inch last on

Fee Rs. 2700/-

Paid on: 18.01.2017.

Dated at Daman.

This 23.01.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.
Chief Inspector of Boilers
Admn. of Daman & Diu (U.T.)