

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler G-73

Type of Boiler. Flue Tube Shell type with
tube Heater.

Boiler Rating 89.82 Sq.mts.

Place and year of manufacture Pune 1990.

Maximum continuous Evaporation 3000 Kg/Hr.

Name of Owner M/s. Jupiter Distillery.

Situation of Boiler. Kathiria, Nani Daman.

Repairs -

Remarks -

Hydraulically Tested on 21.06.2017 to 15.8 Kg/Cm Ibs. per sq. inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 250 PSI Ibs. to the square inch for the period from 21.06.2017 to 20.06.2018.

The loading of the 25 mm Ø Spring Loaded safety valve is not to exceed 10.54 Kg/Cm.

I further certify that the main steam-pipe was tested hydraulically to pressure of per square inch last on

Fee Rs. 3400/-


Paid on: 17.06.2017.

Dated at Daman.

This 21.06.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.