

FORM VI

BOILER INSPECTORATE DEPARTMENT
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Registry Number of Boiler DNH- 73

Type of Boiler. Hor. Multitubular Shell type Boiler

Boiler Rating 135.54 Sq.mts.

Place and year of manufacture Pune, 2012.

Maximum continuous Evaporation 6300 Kg/Hr.

Name of Owner M/s. Reliance Industries Ltd.,

Situation of Boiler. Kharadpada, Silvassa.

Repairs -

Remarks Boiler to be operated by qualified Boiler Attendant.

Hydraulically Tested on 23.06.2017 to 309 Ibs. per sq. inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 206 Ibs.to the square inch for the period from 23.06.2017 to 22.06.2018.

The loading of the 2 nos 50mmØ S.L. safety valve is not to exceed 206 PSI.

I further certify that the main steam-pipe was tested hydraulically to a pressure of 412 Ibs. Square inch last on 02.07.2013.

Fee Rs. 4500/-

Paid on: 30.06.2017.

Dated at Silvassa.

This 23.06.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.
Chief Inspector of Boilers
Administration of Dadra & Nagar Haveli