

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler DNH S 011

Type of Boiler. Small Industrial Boiler

Boiler Rating 12.8 Sq. mts.

Place and year of manufacture Pune 2013.

Maximum continuous Evaporation 600Kg/Hr

Name of Owner M/s. Sangita Industries.

Situation of Boiler. Sr.No 211/5, Dadra, Silvassa.

Repairs -

Remarks Boiler to be operated by Qualified Boiler Attendant.

Hydraulically Tested on 11.08.2017 to 100 lbs. per sq.inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 100 lbs.to the square inch for the period from 11.08.2017 to 10.08.2018.

The loading of the 2nos 25mmØ S.L safety valve is not to exceed 100 PSI

I further certify that the main steam-pipe was tested hydraulically to pressure of 100 lbs. per square inch last on 27-8-2013

Fee Rs. 2100/-


Paid on: 10.08.2017.

Dated at Silvassa.

This 11.08.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.
Chief Inspector of Boilers
Administration of Dadra & Nagar Haveli
SILVASSA