

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler DU-20

Type of Boiler. Horizontal Multitubular Shell
Type.

Boiler Rating 16.11 Sq.mts.

Place and year of manufacture Pune 2010.

Maximum continuous Evaporation 750 Kg/Hr.

Name of Owner M/s. Siyaram Silk Mills Ltd.

Situation of Boiler. Somnath, Daman.

Repairs -

Remarks Boiler to be operated by qualified Boiler Attendant.

Hydraulically Tested on 09.08.2017 to 275PSI lbs. per sq. inch.

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923, to be worked at the maximum pressure of 150 PSI lbs. to the square inch for the period from 09.08.2017 to 08.08.2018.

The loading of the 2 nos. Single Post S.L safety valve is not to exceed 150 PSI.

I further certify that the main steam-pipe was tested hydraulically to pressure of 300 PSI lbs. square inch last on 09.03.2011.

Fee Rs. 2100/-

Paid on: 28.07.2017.

Dated at Daman.

This 09.08.2017.

Inspector



Countersigned.

Chief Inspector of Boilers
Admn. of Daman & Diu (U.T.)
DAMAN

Chief Inspector of Boilers.