

FORM VI

BOILER INSPECTORATE DEPARTMENT

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler DU-29

Type of Boiler. Hor. Multitubular Shell
type Smoke tube Wet back.

Boiler Rating 154 Sq. mts.

Place and year of manufacture Pune 2013.

Maximum continuous Evaporation 4000 Kg/Hr.

Name of Owner M/s. Sovereign Pharma Pvt. Ltd.

Situation of Boiler. Srv no.46/1-4, Kadaiya Village, Daman.

Repairs -

Remarks Boiler to be operated by qualified Boiler Attendant.

Hydraulically Tested on 04.10.2017 to 275 PSI

I hereby certify that the above described boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Indian Boilers Act No. V of 1923 to be worked at the maximum pressure of 150 lbs. to the square inch for the period from 04.10.2017 to 03.10.2018.

The loading of the 2 nos 40mm Ø safety Valve is not to exceed 150 PSI.

I further certify that the main steam-pipe was tested hydraulically to pressure of 300 lbs. per square inch last on 08.11.2013

Fee Rs. 4500/-

Paid on: 16.09.2017.

Dated at Daman.

This 04.10.2017.

Inspector

Countersigned.



Chief Inspector of Boilers.

Chief Inspector of Boilers
Admn. of Daman & Diu (U.T.)